



AURANGABAD MUNICIPAL CORPORATION
FIRE BRIGADE
TELEPHONE NO-2334000-40FAX No-2331444

Outward No:AMC/FIRE / 698 /2021

Date 12 / 10 /2021

To,
Principol,
Om Shikshan Prasarak Mandal Beed
Through President Ganesh V. Jahagirdar,
Himalaya Public School Building,
Arjun Nagar Beed By Pass,
Gut No. 137, At. Balapur Ta & Dist. Aurangabad.

Sub:- Final Fire NOC is issued to Himalaya Public School Building,
Arjun Nagar Beed By Pass, Gut No. 137, At. Balapur Ta & Dist. Aurangabad.

Ref:- 1) Your letter dated 02/09/2021 2) Provisional Noc on date 10/09/2021
2) Your Letter dated 11/10/2021 4) CFO Inspection on dated 11/10/2021.


With Reference to the above subject Final Fire NOC is issued to Himalaya Public School Building, Arjun Nagar Beed By Pass, Gut No. 137, At. Balapur Ta & Dist. Aurangabad. Plot area is 6000.00 Sq Mtr.

Sr. No	Name of Building	Height of Building	Bilding No.	No of floors	Area of Plot	Buitup area	Fire Fund Fees	NOC Fees Rs
1	Himalaya Public School Building	09.35	1	G + 2	6000.00	2948.38	25000	10000

Following Fire prevention and Fire protection & Fire Fighting measures subject to the Himalaya Public School Building Is provided. The School building is having sufficient fire fighting and fire protection measures. The School is fully safe from fire.

1. Open space all around the building shall be provided for the movement of fire tender and which will carry 25 tons. weight capacity.
2. Overhead water tank 25000 lit with of suitable Capacity with Main pump-7.5 HP (180 LPM) -01 Nos for building is provided.
3. 01 Nos Fire service inlet 2 way incoming is provided.
4. 02 Nos.Down Commer system having outlet on all floors with Hose pipe-03 / Branch-3 is provided.
5. Main Staircase 2.00 mtr. & Fire Escape Staircase 1.5 Mtr provided.
7. 06 Nos. Hose reel of 100 feet on all outlets is provided.
- 8 Fire Extinguisher of ABC- 6 Kg-17 Nos of suitable capacity / quantity is provided.
- 9 Fire alarm System (Detection)/ Manually Call Point / Sprinklar System / Smoke Detector System Shall be Provided.
- 10 This Certificate shall be treated valid for a period of one year from the date of issue of Fire Noc.
- 11 Fire Noc is valide for one year & Noc should be renewed each year.

As per BMC ACT -1949 section 376, Development control Rules of 1983 and Maharashtra Fire prevention & Life safety Measures Act 2006. Final Fire NOC is issued to the Principol, Om Shikshan Prasarak Mandal Beed Through President Ganesh V. Jahagirdar, Himalaya Public School Building, Arjun Nagar Beed By Pass, Gut No. 137, At. Balapur Ta & Dist. Aurangabad.


12-10-2021
Chief Fire Officer
Fire Brigade
Municipal Corporation Aurangabad

Copy to:- 1. A D.T.P AMC, Aurangabad.